Series 94 Actuator For A/C Modulating Service



Installation, Operation and Maintenance Manual



File: assembly/manuals/Series 94 A/C Modulating Svc Manual Page 1 of 26

Table of Contents

DHC-100 Introduction	3
FEATURES	3
Series 94 Electric Actuator Introduction	4
Description	4
Electrical Requirement	4
Installation	5
Electrical	5
Type 21 Ball Valve	6
Type 23 Ball Valve (3-way)	6
Type 57 / 57L Butterfly Valves	6
Actuator Mounting Dimensions	7
Operation	8
Manual Override Operation	8
Setting Limit Switches	
Calibration	9
Outline Diagram	9
QuickCal Procedure	10
Aux Open/Close Option Setup	11
Aux Position Option Setup	
Power / Signal (J2)	
Actuator (J1)	
Override (J7)	12
Mode	13
Adjust up and Adjust down	13
Override Mode	
Auto	
Manual/FB Pot Cal	15
Close	15
Open	15
Auxiliary Close Output	
Auxiliary Open Output	
Command Type	
Loss of Command	17
Auxiliary Position Out Cal	17
Fault Indicator	
Stall Detection	
Electronic Brake	19
Duty Cycle Control	
Option Modules	
Series 92 Options Codes for Serial # Tags	
Specifications	
DHC-100 Specs	
Series 92 Specs	
Troubleshooting	

Maintenance	26
Spare Parts	26

DHC-100 Introduction

The DHC-100 is a high performance digital positioner intended to control AC actuators, providing 450 points of resolution with quarter turn actuators ranging from 2 sec to 120 sec and rated for 25% duty or more. The DHC-100 has many automatic advanced features that will enhance any actuator while making it easy to install and set up.

The simple three button control is used to configure all parameters the unit needs for a wide variety of applications, and allows the *open* and *closed* positions to be easily set for direct or reversing acting without any rewiring. The unit can be configured for various command types (4-20mA, 1-5V, 0-5V, 0-10V, or a digital command) and its default operation upon loss of command.

Various option modules are easily plugged into the unit, providing other features such as a position feedback signal (current or voltage), auxiliary switches, fault relay contact, or digital communications. A wide range of data is accessible through a digital communications module, providing additional control or information.

The unit is of single solid construction and is easily mounted with two screws.

FEATURES

- Positions to ±0.1° with quarter-turn actuators ranging from 2 sec to 90 sec.
- Three button control provides easy setup and eliminates the need for instrumentation.
- Polarity Detection feature allows direct or reverse acting operation without re-wiring.
- Electronic Brake feature can eliminate need for a mechanical brake in many applications, and extends mechanical brake life when used.
- Stall Detection feature protects actuator motor from a stall condition.
- Automatic Duty Cycle Control feature prevents shutdown of a process due to a thermal overload of the actuator motor, and allows actuators rated for 25% duty or more to be safely used.
- Operating temperature range of 0 to 60°

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Page 3 of 26

Series 94 Electric Actuator Introduction

Description

The Series 94 electric actuators feature a reversing, capacitor run motor, and a permanently lubricated gear train. These actuators are equipped with integral thermal overload protection (AC models) with automatic reset, independently adjustable limit switches, declutchable manual override, visual position indication, Zytel FR50 enclosure with stainless steel trim, ISO bolt circle, and 2 (two) ½" NPT conduit entries.

Standard models are offered in 115 VAC, feature an enclosure meeting Nema-4X, and provide up to 300 in-lbs. of output torque.

The DHC-100 is easily mounted with 2 screws and is equipped with removable screw terminals that provide for easy field wiring.

A simple three button control allows the user to perform a complete set-up from the unit itself without the need for any instrumentation. The adaptive control feature of the DHC-100 eliminates the need for any calibration steps. In the simplest application, only the *closed* and *open* positions need to be set and the unit automatically and continuously sets all other parameters when placed in the AUTO mode.

CAUTION: These units are intended to be mounted in an appropriate enclosure to avoid electrical shocks. High voltages are present on the outside of the unit when power is applied. AC power should be disconnected prior to any wiring of these units. A heater and thermostat should be used where condensation may occur.



Electrical Requirement

<u>CAUTION:</u> Proper voltage must be supplied to actuator/positioner package or the result could be a damaged positioner, a damaged actuator, or both.

<u>MOTE:</u> To conform to various electrical codes, a green grounding screw has been installed (on the baseplate) inside of actuator.

The DHC-100 is rated for motors with up to 5A running currents and comes in three versions to accommodate different voltage applications. The DHC-100 is rated for 117 VAC $\pm 10\%$; the DHC-100A is rated for 234 VAC $\pm 10\%$, and the DHC-100B is rated for 24 VAC $\pm 10\%$.

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Rev. B 4/1/06

Installation

Electrical Reference Drawing #297QM

- To gain access to terminal strip (Part #8 & 9) it is necessary to remove manual override handle (Part #34) by loosening slotted setscrew (Part #35). Remove 8 cover screws and cover.
- Make electrical connections to terminal strip as shown on wiring schematic located inside the cover (per various electrical codes there is a green screw on the actuator base plate for grounding purposes). All units are completely calibrated prior to shipment, and no internal adjustments should be required.
- 3. Install 1/2" NPT conduit fitting(s) to actuator base. Please ensure that proper conduit fitting is used to maintain NEMA 4X enclosure rating.

NOTE: We recommend sealing conduit openings on units installed outdoors or exposed to large temperature swings (15°F or more).

We also recommend the heater and thermostat option in these applications.

4. Replace actuator (gasket if removed) cover, and install 8 cap screws supplied and tighten securely. For outdoor or wet locations it is recommended prior to replacing the cover that the top shaft seal be cleaned and coated with silicone grease. Also clean shaft and lightly coat seal area of shaft with silicone grease. Unit is now ready for operation.

ſ			115	Vac	230	Vac	12	Vdc	24	Vdc	12	Vac	24	Vac	Cycle	
	Model	Torque (in/lbs)												Cycle	Time per 90 Degrees (Seconds)	Weight (lbs)
Ī	A94	150	0.5	100%	0.4	100%	2.0	75%	4.0	75%	2.0	75%	4.0	75%	5	3.5
ľ	B94	300	0.8	75%	0.6	75%	2.0	75%	4.0	75%	2.0	75%	4.0	75%	5	3.5

Note: Amp rating is considered locked rotor

Duty cycles are for ambient temperature (73° F)

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Rev. B 4/1/06 Page 5 of 26

Type 21 Ball Valve

Position the valve and the actuator to corresponding positions (either OPEN or CLOSED). The flats on the actuator shaft extension indicate valve position

Type 21 Ball Valves (See Drawing #0106BV sizes ½" - 2")

Install mounting bracket #3 to actuator #2 using bolts #8 and washers #9. Insert coupling #4 on stem of valve #1 and then bolt valve #1 to mounting bracket #3 using bolts #5, nuts #7, and washers #6.

Note: All bolts should be snug and not excessively over tightened.

Type 21 Ball Valves (See Drawing #0112BV sizes 2-1/2" - 3")

Install mounting bracket #3 to actuator #2 using bolts #8 and washers #9. Insert coupling #4 on stem of valve #1 and then bolt valve #1 to mounting bracket #3 using bolts #5, nuts #7, and washers #6.

Note: All bolts should be snug and not excessively over tightened.

Type 23 Ball Valve (3-way)

Position the valve and the actuator to corresponding positions (either OPEN or CLOSED). The flats on the actuator shaft extension indicate valve position

Type 23 Ball Valves (3-way): (See Drawing #0129BV, sizes ½" - 3") Install mounting bracket #3 to actuator #2 using bolts #8 and washers #9. Insert coupling #4 on stem of valve #1 and then bolt valve #1 to mounting bracket #3 using bolts #5, nuts #7, and washers #6.

Type 57 / 57L Butterfly Valves

CAUTION: If valve is in line, system must be shut down and have no line pressure before removing throttle plate and retaining washer.

Position the valve and the actuator to corresponding positions (either OPEN or CLOSED). The flats on the actuator shaft extension indicate valve position

Butterfly Valves (See Drawing # 0203BF57 sizes 1-1/2" - 4")

No specially machined stem or valve body drilling required. Remove handle (remove handle cap and hex head bolt) to expose throttle plate screws. Remove throttle plate and retaining washer to expose existing bolt pattern. Mount bracket #3 to actuator #2 with bolts #8 and washers #9 and tighten evenly. Insert coupling #4 into actuator #2.Install valve #1 onto mounting bracket #3 and align stem of valve to engage with coupling. (Line scribed on top of stem


File: assembly/manuals/Series 94 A/C Modulating Svc Manual Rev. B


indicates disc orientation). Install bolts #5, washers #6 and nuts #7 and tighten evenly. Flats on actuator shaft indicate valve position. (Disc Orientation)





<u>CAUTION:</u> If mounted unit is installed other than straight up, the actuator should be supported independently to prevent side loading and loosening up of fasteners.

Actuator Mounting Dimensions









File: assembly/manuals/Series 94 A/C Modulating Svc Manual Page 7 of 26

Operation

Manual Override Operation Reference Drawing #279QM

Push down on handle (Part #34) and rotate within labeled limits.

To re-engage simply rotate actuator handle in opposite direction until it moves up and re-engages.

CAUTION: The manual override should only be used when there is no power applied to actuator. When power is restored the actuator will automatically resume normal operation.

Setting Limit Switches Reference Drawing #279QM



Disconnect power!

Open Travel Limit Switch (SW-2 Part #14):

Using declutchable manual override, move the valve approximately 2 degrees beyond the full open position. Then loosen set screws on top cam (Part #21) and rotate cam (CCW) into limit switch arm until a click is heard, this designates the switch circuit has opened and defines a full open position. Tighten 2 set screws (Part #22) on cam.

Close Travel Limit Switch (SW-1 Part #14):

Using declutchable manual override, move the valve approximately 2 degrees beyond the full closed position, loosen set screws on bottom cam (Part #21) and rotate cam (CW) into limit switch arm until a click is heard, this designates the switch circuit has opened and defines a full closed position. Tighten 2 set screws (Part #22) on cam.

CAUTION: The limit switches inside of the unit are for loss of signal conditions; NOT for normal operation of the modulating actuator.


Manually position valve to midstroke. Reapply power to actuator and drive to open or closed position. Actuator motor will run. The shaft will not turn until internal gearing re-aligns with drive gear. This could take up to 10 seconds.

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Page 8 of 26


Calibration

Outline Diagram


DHC-100 117VAC DHC-100A 234VAC DHC-100B 24VAC




FRONT PANEL



ELECTRICAL CONNECTIONS





J3 OPTION MODULE CONNECTOR

— to Auto/Manual Station—	J/
OVERRIDE INPUT 2	$ \oslash $
- · - · - ·	

QuickCal Procedure

The following is a quick calibration procedure. For more details regarding the calibration and features of your DHC-100, please see the pages following this procedure.

General

The MODE button selects a particular function, or mode, and the indicator for the selected mode turns on steady. Pushing the MODE button saves any new setting of the current mode before switching to the next mode. The adjust up (\blacktriangle) and adjust down (\blacktriangledown) buttons are used to make adjustments to current mode.

- 1. Apply power to the actuator on Connector J2: terminal #1 (neutral), terminal #2 (line), and terminal #3 (earth). There is no need for a signal connection during calibration.
- 2. Push the MODE button until the yellow "MANUAL/FB POT CAL" LED is illuminated. The LED may be flashing (at different speeds) through the next several steps. This is expected and will be explained.
- 3. Use the adjust buttons (▲ and ▼) to move the actuator and verify that the limit switches are set past the desired open and closed positions; then move the actuator to mid stroke.
- 4. If LED is solid, proceed to step 7.
- 5. If LED is flashing, loosen the gear on the actuator shaft and rotate the potentiometer gear until the LED is no longer flashing, but on solid this indicates the center of the potentiometer's travel. Note that the LED will flash at a slower rate the farther away from the mid position it gets. Once the LED is on solid tighten all gears.
- 6. Push the MODE button until the "CLOSE" LED is illuminated. Use the adjust buttons (▲ and ▼) to drive the actuator to the desired closed position. Ensure that the close limit switch does not engage.
- 7. Push the MODE button until the "OPEN" LED is illuminated. Use the adjust buttons (▲ and ▼) to drive the actuator to the desired open position. Ensure that the open limit switch does not engage.
- 8. Please skip to **Aux Open/Close Setup** if optional Transmitter with Relays is installed; otherwise continue to the next step.
- 9. Push the MODE button until the "COMMAND TYPE" LED is illuminated. Use the adjust buttons (▲ and ▼) to select appropriate input signal (4-20mA, 1-

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Rev. B 4/1/06 Page 10 of 26

- 5VDC, 0-5VDC, 0-10VDC, or Digital). If 0-5VDC or 0-10VDC is selected, the LOSS OF COMMAND feature is not available, so proceed to step 12.
- 10. Push the MODE button until the "LOSS OF COMMAND" LED is illuminated; this sets the actuator to a predetermined position upon loss of command. Use the adjust buttons (▲ and ▼) to select appropriate position (OPEN, CLOSE, or LAST POSITION).
- 11. Please skip to **Aux Position Setup** if optional Transmitter with Relays is installed, otherwise continue to the next step.
- 12. Push the MODE button until the "AUTO" LED is illuminated. Your calibration is now **COMPLETE**. Connect the command signal wires to connector J2: terminal #4 (signal ground) and terminal #5 (mA input) **OR** terminal #6 (voltage input), depending on the application. If a signal input was already connected, the actuator should have moved to that position.

Aux Open/Close Option Setup

- Push the MODE button until the "AUX CLOSE OUTPUT" LED is illuminated.
 Use the adjust buttons (▲ and ▼) to drive the actuator to the desired auxiliary close position.
- 2. Push the MODE button until the "AUX OPEN OUTPUT" LED is on. Use the adjust buttons (▲ and ▼) to drive the actuator to the desired auxiliary open position.
- 3. Continue with Step 9 in the **Quick Calibration Procedure** (see above).

Aux Position Option Setup

- Push the MODE button until the red "AUX POSITION OUT CAL" LED illuminates while the "CLOSE" LED flashes. Note that the red LED flashes to indicate a "Fault" and turns on steady to indicate the "AUX POSITION OUT CAL" modes.
- 2. Use the adjust buttons (▲ and ▼) to set the desired output voltage or current (mA) on the option module output for the closed position.
- 3. Push the MODE button so the "AUX POSITION OUT CAL" LED remains steady **while** the "OPEN" LED flashes. Use the adjust buttons (▲ and ▼) to set the desired output voltage or current (mA) on the option module output for the open position.
- 4. Continue with Step 12 in the **Quick Calibration Procedure** (see above).

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Page 11 of 26

Please read the following pages to ensure that ALL of the selectable features are understood and selected if required.

Power / Signal (J2)

Power is connected to pins 1, 2, and 3 as shown in the block diagram. The fuse installed on the unit is rated for maximum output current that can be safely delivered by the AC outputs. Replacement fuses must not exceed the maximum rating to prevent damage to the unit.

An appropriate command signal, either 0-5V, 0-10V, 1-5V, or 4-20mA, should be connected to pin 5 or 6 (as shown in the Block Diagram) while using pin 4 as the return signal ground. The DHC-100 must be configured for the type of command signal that is to be used (see COMMAND TYPE).

Pin 7 of J2 provides an auxiliary +5V output which can be used to connect a command potentiometer. By connecting one end of a potentiometer to pin 7, the other end to pin 4, and the wiper to pin 6, a local control knob can be implemented. Pin 8 provides an auxiliary +15VDC output which can be used to power an input or output 4-20mA transmitter.

Actuator (J1)

The actuator motor and feedback potentiometer are connected to J1 as shown in the Block Diagram. The Motor Neutral wire must be connected to pin 2, while one motor winding is connected to pin 1 and the other winding to pin 3. The feedback potentiometer wiper must be connected to pin 5, while one end is connected to pin 4 and the other end to pin 6. The Polarity Detection feature of the DHC-100 automatically determines which motor winding to control based on where the open and closed positions are set; this feature also eliminates the need to rewire the unit for direct or reverse acting applications.

When the ▲ and ▼ buttons are used to control the actuator, the ▲ button will turn on the motor winding connected to pin 1, while the ▼ button will turn on the motor winding connected to pin 3. See MANUAL/FB POT CAL for more details.

Override (J7)

J7 provides a simple 2-wire connection that can override the DHC-100 to perform a variety of external control functions. Using an appropriate interface module, commonly used auto/manual station switches are easily implemented with low voltage/low current switches. The factory-installed jumper between pins 1 and 2

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Rev. B 4/1/06 enables normal operation of the DHC-100 and <u>must</u> be installed if the external override functions are not used.

<u>Mode</u>

The MODE button is used to select the desired function of operation. When the MODE button is pressed, the unit will switch to the next function and the appropriate LED indicator will turn on to let the user know which function is selected. Except for the MANUAL/FB POT CAL mode, the associated mode indicator will be steady on; for some of the modes other indicators will flash to indicate specific settings associated with the mode. Each of the modes are described in more detail in the following sections.

If a 0-5V or 0-10V command signal is used, the LOSS OF COMMAND function cannot be used. The MODE button will skip over the LOSS OF COMMAND mode when the unit is configured for a 0-5V or 0-10V command signal (see COMMAND TYPE). When the OVERRIDE mode is enabled (see OVERRIDE MODE), the MODE button is disabled and the Manual/Pot Cal indicator will turn on steady.

Adjust up and Adjust down

The adjust up ▲ and adjust down ▼ buttons are used to adjust the setting of any given function. When a function is selected by the MODE button, the adjust buttons will affect that function only. Note, that the AUTO mode does not have any adjustable settings, and therefore, the adjust up and adjust down buttons have no effect. Also, the adjust buttons are disabled in the OVERRIDE mode.

Override Mode

The OVERRIDE mode is not selected by the MODE button and can be enabled at anytime by connecting a resistance greater than 250 ohms to the Override Input (J7 pin 1 and pin 2). While the OVERRIDE mode is enabled, the MODE button and adjust buttons are disabled, and the Manual/Pot Cal indicator will turn on steady to indicate that the unit is being controlled by the Override Input. Shorting J7 pin 1 to pin 2 returns the unit to normal operation and the previously selected mode. Note that earlier models may not have connector J7, and therefore do not have the OVERRIDE mode feature.

Controlling the DHC-100 from the Override Input is accomplished by connecting a specific resistance to select a specific operation. The table below defines the operations and their associated resistance.

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Page 13 of 26

RESISTANO	<u>CE</u>	OPERATION
> 4.3K ohms	3	OFF
3.3K ohms	±5%	LATCH
2K ohms	±5%	OPEN
1.2K ohms	±5%	CLOSE
510 ohms	±5%	STOP

The OPEN function will operate the motor in the *open* direction as set by the OPEN mode, while the CLOSE function operates the motor in the *closed* direction as set by the CLOSE mode. The LATCH function will maintain the previously selected function; this allows momentary switches to be used for the OPEN and CLOSE functions. The OFF and STOP functions turn the motor off, which also unlatches the OPEN or CLOSE functions.

Note that the OPEN and CLOSE functions may work in reverse until the *open* and *closed* positions are set by the OPEN and CLOSE modes. The DHC-100 will automatically turn the motor off when the *open* or *closed* positions are reached. However, if a feedback fault occurs (see FAULT INDICATOR), the motor will be turned on for a period of 15 minutes in the selected direction. For this reason, limit switches should be used when using the OVERRIDE mode, and should be set to a position acceptable for the application. The 15 minute period can also be terminated using the OFF or STOP function.

The motor is also automatically turned off if the DHC-100 detects a stall (see STALL DETECTION). An OPEN or CLOSE operation can be attempted again after switching to the OFF, LATCH, or STOP functions first.

<u>Auto</u>

The AUTO function is the normal mode of operation for the DHC-100; all the other functions are used to set up the unit. While in AUTO, the unit can be controlled by various external signals, some of which can be selected by the COMMAND INPUT function. When the unit is <u>not</u> in the AUTO mode, all external controls described below will be disabled.

Once the *open* and *closed* positions have been set, the AUTO mode will control the position of the actuator according to the command input signal. For an input signal of 0V (for 0-5V or 0-10V input), 1V (for 1-5V input), 4.0 mA (for 4-20mA input), or 0% (for a digital input), the DHC-100 will position the actuator to the *closed* position as set by the user. Conversely, an input of 10V, 5V, 20mA, or 100% will position the actuator to the defined *open* position.

When the DHC-100 is configured to use a 0-5V, 0-10V, 1-5V, or 4-20mA command, the command signal should be connected to the appropriate pin on J2 - note that the unused input pin <u>must</u> be left unconnected. When the DHC-100 is configured for a Digital command type, an appropriate communications option module must be installed. A communications module may be installed when using one of the analog command types and can be used to override the analog

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Page 14 of 26 command. The AUTO indicator will flash whenever the communications module is controlling the unit.

Manual/FB Pot Cal

The MANUAL/FB POT CAL function allows manual operation of the actuator by using the adjust buttons (▲ and ▼) without affecting any other settings within the DHC-100. When the ▲ button is pressed, the motor winding connected to J1-1 is turned on while the ▼ button turns on the J1-3 winding. Whether the actuator moves toward the *open* or *closed* position depends on which motor winding is connected to J1-1 and J1-3.

The POT CAL feature provides an indication of the feedback potentiometer's setting. When the MANUAL/POT CAL function is selected, the Manual/Pot Cal indicator will turn on - it may flash or be on steady, depending on the actuator position. The indicator will be on steady whenever the DHC-100 detects that the feedback potentiometer is at midrange of its rotation. As the actuator moves, causing the feedback potentiometer to move away from midrange, the indicator will begin to flash, and the indicator will flash at a decreasingly slower rate as the actuator moves further away from midrange.

By using the adjust buttons to position the actuator to midstroke (half way point between the desired *open* and *closed* positions), the feedback potentiometer can then be adjusted until a steady light occurs. This insures that the feedback potentiometer has maximum range to reach the *open* and *closed* positions.

<u>Close</u>

The CLOSE function is used to set the desired *closed* position; however, prior to doing this, the feedback potentiometer should be checked for optimum position (see MANUAL/POT CAL), and the limit switches should be set outside of the operating range (see STALL DETECTION FEATURE). In the CLOSE function, the adjust buttons are used to set the actuator to any desired position, and upon pressing the MODE button (to select the next function, OPEN), the DHC-100 will retain the setting as the defined *closed* position.

Upon selecting the CLOSE function, the DHC-100 will begin moving the actuator to the previously set *closed* position; it is not necessary to make an adjustment if the unit has been previously set to the desired position. A command signal input of 0V, 1V, 4mA, or 0% automatically corresponds to the defined *closed* position.

Open

The OPEN function works the same way as the CLOSE function with the exception that the adjust buttons are used to set the desired *open* position. As

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Page 15 of 26 with the CLOSE function, upon selecting the OPEN function, the actuator will move to the previously set open position. Once the desired position is set, the DHC-100 will automatically correspond a command signal input of 10V, 5V, 20mA, or 100% to the *open* position.

Auxiliary Close Output

The AUX CLOSE OUTPUT function is used to set an optional output setting that is associated with the *closed* position - an appropriate relay option module is required to use this output. The adjust buttons are used to set the actuator to a desired position. Whenever the actuator position falls between the defined closed position and the Aux Close position, the Aux Close Output indicator will flash. Additionally, the DHC-100 will turn on a relay output on the optional relay module - the output can be used to drive an alarm or merely act as an auxiliary limit switch. Relay is rated for 1 amp @ 24VDC or .5 amp @ 115 VAC.

Upon selecting the AUX CLOSE OUTPUT function, the DHC-100 will begin moving the actuator to the previously set position. It is not necessary to make an adjustment if the unit has been previously set to the desired position.

Auxiliary Open Output

The AUX OPEN OUTPUT function is used to set an optional output setting that is associated with the open position - an appropriate relay option module is required to use this output. The adjust buttons are used to set the actuator to a desired position. Whenever the actuator position falls between the defined open position and the Aux Open position, the Aux Open Output indicator will flash. Additionally, the DHC-100 will turn on a relay output on the optional relay module - the output can be used to drive an alarm or merely act as an auxiliary limit switch. Relay is rated for 1 amp @ 24VDC or .5 amp @ 115 VAC. Upon selecting the AUX OPEN OUTPUT function, the DHC-100 will begin moving the actuator to the previously set position. It is not necessary to make an adjustment if the unit has been previously set to the desired position.

Command Type

The COMMAND TYPE function is used to configure the command signal input for either 4-20mA, 1-5V, 0-5V, 0-10V, or digital so as to match the type of command signal being used. Upon selecting the COMMAND TYPE function, the Command Input indicator will turn on steady, while the indicator for the selected type will flash. Use the adjust buttons (▲ and ▼) to select the desired input type. The selection will be saved when the MODE button is pressed, which will also advance the unit to the LOSS OF COMMAND function.

File: assembly/manuals/Series 94 A/C Modulating Svc Manual 4/1/06 Rev. B

Loss of Command

When using 1-5V, 4-20mA, or a Digital input type for the command signal, the DHC-100 will detect when the command signal is lost or out of range. A loss of command condition is detected whenever the input is disconnected, the input becomes less than 0.75V or 3mA, or the input becomes greater than 5.5V or 22mA. If the DHC-100 detects a loss of the command signal, the Fault indicator will flash and the actuator will be moved to one of three preset positions: the *open* position, the *closed* position, or the position last attained prior to losing the command signal. The LOSS OF COMMAND function is used to set the desired default position.

When the LOSS OF COMMAND function is selected, the adjust buttons ▲ and ▼ are used to set the default position. The DHC-100 indicates the selected default setting by flashing the Open function indicator for the *open* default position, or it will flash the Close function indicator for the *closed* default position. When neither indicator is on, then the "last position" default is selected.

When a 0-5V or 0-10V command signal is used, a loss of command signal cannot be detected. Therefore, if the unit is configured for a 0-5V or 0-10V command signal (see COMMAND INPUT), the MODE button will not select the LOSS OF COMMAND function.

Auxiliary Position Out Cal

Note that the AUX POSITION OUT CAL indicator also serves as a Fault indicator. When the indicator is on steady, the AUX POSITION OUT CAL function is selected. When the indicator flashes, a Fault condition has been detected (see FAULT INDICATOR for details). The AUX POSITION OUT CAL function is used to calibrate an optional feedback transmitter output. An appropriate transmitter option module is required to use this feature.

When the AUX POSITION OUT CAL function is first selected (by pressing the MODE button while in the LOSS OF COMMAND function), the CLOSE indicator will flash, and the voltage or current associated with the *closed* position will appear at the option module output. If desired, the output can be adjusted (using the adjust buttons ▲ and ▼) to any value from 0 to 10V (for a voltage output) or 0 to 20mA (for a current output). The new setting is then associated with the *closed* position.

Pressing the MODE button again will leave the unit in the AUX POSITION OUT CAL function except that the OPEN indicator will flash, and the output voltage or current associated with the *open* position will appear at the option module output. Like the *closed* setting, the output can be adjusted to any voltage (from 0 to 10V) or current (from 0 to 20mA), and the new setting is then associated with the *open* position.

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Rev. B 4/1/06
Page 17 of 26

Fault Indicator

The DHC-100 detects various fault conditions that prohibit the unit from controlling the actuator. When any of these conditions are detected, the Fault indicator will flash, and the motor outputs are turned off until all fault conditions have been corrected. If an appropriate relay option module is installed, the Fault relay output on the option module will also turn off. A communications option module can read the specific condition(s) causing the fault. Note that a fault condition DOES NOT disable the motor outputs when manually controlling the actuator with the adjust buttons; while useful for troubleshooting, care should be excercised when operating the motor under a fault condition. The OVERRIDE mode can also operate the motor when a fault condition exists - see OVERRIDE MODE for details. The various fault conditions are described below:

LOSS OF COMMAND - If the command signal is disconnected or out of range, the fault indicator will remain on until the signal is reconnected or back in range.

FEEDBACK POT FAULT - A fault condition is detected whenever the feedback signal is out of range (that is, less than 5% of the potentiometer value or more than 95% of the potentiometer value), or when any of the potentiometer connections are broken. Normal operation resumes when the potentiometer is reconnected or back in range.

MOTOR 1 STALL - A fault condition is detected when no actuator motion is detected while the Motor 1 output is turned on. The fault condition will disable the Motor 1 output only, and the fault is cleared when the DHC-100 detects a motion greater than 1.5° in either direction. The fault can be cleared if 1) the command signal commands a Motor 2 operation, 2) manual operation with the adjust buttons results in a motion greater than 1.5°, or 3) a mechanical manual override forces the 1.5° motion, provided the mechanical motion is monitored by the feedback pot.

MOTOR 2 STALL - A fault is detected when no actuator motion is detected while the Motor 2 output is turned on. The fault can be cleared in the same manner as a Motor 1 Stall (see above).

DOUBLE STALL - If the DHC-100 detects no actuator motion in either direction, both motor outputs will be disabled. The command signal cannot clear this condition; only manual operation or a mechanical override can clear the fault. Alternatively, the DHC-100 can be powered off and then on to temporarily clear the fault; however, this practice should be avoided without permanently correcting the cause of such a fault.

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Rev. B 4/1/06 Page 18 of 26

Stall Detection

The **Stall Detection** feature of the DHC-100 (see FAULT INDICATOR) essentially performs a similar function as commonly used torque switches.

The **Stall Detection** feature is useful for detecting when any of the motor wires become disconnected. However, limit switches employed in actuators essentially disconnect one of the motor windings. The DHC-100 will detect this as a motor stall. To avoid this condition, the limit switches must be set outside of the operating range set by the CLOSE and OPEN functions.

Electronic Brake

The **Electronic Brake** feature of the DHC-100 provides highly reliable and accurate braking of the motor, and it is a key element in achieving high resolution. A mechanical brake can still be implemented without interfering with the DHC-100 operation. Mechanical brakes can be useful for providing a holding brake in the event power to the actuator is lost.

Since the **Electronic Brake** feature provides the primary braking of the motor, the life of a mechanical brake is dramatically extended. Additionally, the **Adaptive Control** feature of the DHC-100 automatically compensates for changes in a mechanical brake's performance due to temperature or age.

Note that the actuator's limit switches should be set outside of the operating range set by the CLOSE and OPEN functions. The **Electronic Brake** feature degrades in performance if a limit switch is engaged. Limit switches exhibit wide variations, and the DHC-100 can position the actuator more precisely at *closed* and *open* than the limit switches. A limit switch serves better as a fail safe device to protect against electrical failures in the actuator.

Duty Cycle Control

The **Duty Cycle Control** feature of the DHC-100 allows actuators rated at 25% duty or more to be safely used in automated valve applications. The DHC-100 accurately monitors the relative heating of the motor and automatically duty cycles the unit at a safe level when a process becomes unstable, or if a control loop is not properly set. While the thermal switch in the motor protects the motor from overheating, thermal switches can shutdown the actuator for ten minutes or more.


The **Duty Cycle Control** feature allows continuous operation of the motor until it detects an excess heat build up in the motor (usually well below the limit of the thermal switch). At that time, duty cycle operation is automatically enabled and continues until the motor cools enough to resume continuous operation. The duty cycle period is approximately 2 seconds with an on time that automatically various depending on the heating of the motor. While this operation slows down the

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Page 19 of 26

actuator's operation, it does not impact the resolution performance of the DHC-100, and it prevents disruption of a process due to a thermal switch shutdown.

Option Modules

Various option modules can be plugged into the DHC-100 option module connector, J3. Option modules provide additional features such as position feedback signals, auxiliary switch outputs, or digital communications. Contact the factory for the latest available modules. Refer to the diagram below for instructions on installing an option module.



Installing an Option Module

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Rev. B 4/1/06
Page 20 of 26

Series 92 Options Codes for Serial # Tags

M1	1 extra limit switch
M2	2 extra limit switches
HT	Heater & thermostat
Р	Feedback potentiometer
DP	Dual feedback potentiometers
C1	4-20 mA Positioner
M	Mechanical brake
CO	Center off
CLC	Cycle length control
2WC	2-wire control
FS	Failsafe Battery Pak
C3	4-20mA Output Transducer
A4	4-12mA Input Signal Positioner
B12	Split Range Positioner

Example 1: S92HTPXWJ

Heater & thermostat and feedback potentiometer installed.

Example 2: AM92M1XWJ

Mechanical brake and 1 extra limit switch installed.

Specifications

DHC-100 Specs

POWER REQUIREMENTS

DHC-100: 117VAC \pm 10%, 50/60 Hz DHC-100A: 234VAC \pm 10%, 50/60 Hz DHC-100B: 24VAC \pm 10%, 50/60 Hz 12 VA typical (not including output load) Fuse Type: 5A TR5 Slo-Blo (replaceable)

COMMAND SIGNAL INPUT

Input Impedance

20K ohms (1-5 VDC, 0-5 VDC, 0-10 VDC Input)

251 ohms ±1% (4-20 mA Input)

Loss of Command threshold

< 0.75V or > 5.5V (1-5 VDC input)

< 3mA or > 22mA (4-20mA input)

FEEDBACK SIGNAL INPUT

Input Voltage: 0 to 2.5 VDC

External Feedback Potentiometer: 1K ohm

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Rev. B 4/1/06 Page 21 of 26

POWER SUPPLY OUTPUTS

+15V OUT (J2-8): 125mA maximum (not including

option module)

+5V OUT (J2-7): 5mA maximum

NOTE: Do not connect these outputs to other power supplies.

AC MOTOR OUTPUTS

Off-state Leakage Current: <15mA Maximum Load Current @ 150°C: 5A

ENVIRONMENTAL

Operating Temperature Range: 32 °F to 150 °F Storage Temperature Range: -40 °F to 185 °F

Relative Humidity Range: 0 to 90 % (noncondensing)

Series 92 Specs

MOTOR

Brushless Capacitor Run CE Compliant AC Motors

GEAR TRAIN

Permanently Lubricated Rockwell Hardened

MOUNTING CONFIGURATION

ISO Bolt circle (F07) ISO Output Drive

MANUAL OVERRIDE

Fully De-clutchable

ENCLOSURE

NEMA 4X, 7, & 9 Combination Stainless Steel Trim 2 (Two) ½" FNPT Conduit Entries

POSITION INDICATION

Beacon Position Indicator

TEMPERATURE

150° F maximum Ambient Temperature

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Rev. B
Page 22 of 26

Troubleshooting

PROBLEM	POSSIBLE CAUSES	REMEDIES	
There is no output, but the motor runs	Manual override engaged. Valve stem broken.	When the manual override is engaged, the motor will run, but no output will be observed until the manual override re-engages with the output shaft When the valve stem is broken, there will not be a change in fluid movement, making it seem as if the actuator has no output	
No response from valve/actuator	No power source to actuator No signal to actuator Power source disconnected Low or wrong power source Mechanical Brake jammed or misaligned	Check for power Check "Fault Indicator Check for broken wire, loose connection Check for proper voltage Check alignment of brake	
Motor hums and no output is observed	Foreign material caught in valve Capacitor worn	Remove material and inspect valve for damaged and/or worn parts. Replace parts as necessary Replace capacitor	
No response from unit (All lights are off.)	No power Excessive voltage applied to unit. Blown or missing fuse	Check power source. Replace unit. Replace with appropriate fuse; see "Specifications" in manual.	

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Page 23 of 26

PROBLEM	POSSIBLE CAUSES	REMEDIES
No response from unit (MANUAL / FB POT CAL	Jumper wire on J7 terminal block is missing.	Install jumper wire on J7 terminal block.
light is on.)	Auto/Manual station is improperly wired.	Check wiring on Auto/Manual station; see "Override Mode".
Actuator rotates backwards.	Actuator or valve is mounted incorrectly on coupling.	Remount actuator as necessary.
baokwaras.	Actuator needs to be reverse acting.	Refer to "Close" and "Open" modes in manual.
	Input signal not connected	Connect input signal and refer to "Loss of Command" in manual.
	Input signal polarity reversed. Input signal wired to wrong terminal.	Reverse input wires. Check input signal wiring; refer to "Power/Signal J2" in manual.
Actuator does not respond to input signal. (FAULT indicator	Feedback potentiometer improperly wired. Feedback potentiometer	Check wiring; refer to "Actuator J1" in manual.
constantly flashes.)	out of range. Defective feedback potentiometer.	Refer to "Manual/FB Pot Cal" in manual.
	Defective motor brake (holds motor)	Replace feedback potentiometer.
	Defective motor (not turning)	Repair or replace motor brake.
		Repair or replace motor.

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Page 24 of 26

PROBLEM	POSSIBLE CAUSES	REMEDIES	
Actuator does not respond to input signal. (FAULT indicator is off.)	Closed and open positions are set to the same position.	Set closed and open settings; refer to "Close" and "Open" modes in manual.	
FAULT indicator flashes after actuator reaches the fully closed or open position.	Closed or open limit switches set inside the operating range.	Adjust limit switch cams; refer to "Close" and "Open" modes in manual.	
Actuator operates erratically. (FAULT indicator flashes	AC ripple induced on the command input signal. Defective feedback potentiometer Loose feedback potentiometer or loose feedback potentiometer	Use equipment that isolates AC ripple from the command signal. Replace feedback potentiometer. Tighten feedback	
erratically.)	gears Sloppy gear tooth engagement	potentiometer and/or potentiometer gears. Adjust feedback potentiometer gears for tight engagement.	

Maintenance

Disconnect power!

NEVER REMOVE ACTUATOR COVER WHILE CIRCUITS ARE LIVE!



CAUTION: It is imperative for reducing the chance of electrical shock, and to prevent ignition of hazardous atmospheres that you

Disconnect power

before any maintenance or repairs are performed.

Series 94 actuators are virtually maintenance free. We do however, recommend that periodic checks are made to ensure that all fasteners are tight and properly torqued to extend the life of the actuator and valve.

Series 94 Actuators are manufactured with factory lubricated grease in the gear case and gearbox. This lubricant should never have to be replenished.

For outdoor or wet locations keep top and bottom seals coated with a silicone based grease.

Spare Parts Reference Drawing #289S92

We recommend that the following be kept on hand as spare parts.


- 1 --- Limit Switch (Part #14)
- 1 --- Capacitor (Part #13)


NOTE: When ordering replacement motor parts and/or options specify model # and voltage.

Attachments:

7 drawings: 0106BV, 0112BV, 0129BV, 0203BF57, 279QM, M00EL381, M00EL382

File: assembly/manuals/Series 94 A/C Modulating Svc Manual Rev. B 4/1/06
Page 26 of 26





FOR REFERENCE ONLY
ASAHI/AMERICA

UNIT: INCH VALVE 1" 1-1/4" 1-1/2" 1/2" 3/4" SIZE 2.76 3.01 3.29 4.43 Н 3.64 3,98 H1 1.38 1.54 1.85 2.17 2.60 1.14

NOTE. The shape and appearance of assembly differ a little with nominal size compared to this drawing.

9	FLAT WASHER (M6.0)	STAINLESS STEEL	4
8	BOLT (M6.0×1-16LG)	STAINLESS STEEL	4
0		3 I HINLL 33 3 I LLL	7
7	NUT (FDR 1/2" THRU 1-1/4" : M5.0x.8) (FDR 1-1/2" THRU 2" : M6.0x1)	STAINLESS STEEL	4
6	FLAT WASHER (FOR 1/2" THRU 1-1/4": M5.0) (FOR 1-1/2" THRU 2": M6.0)	STAINLESS STEEL	8
5	BDLT (FDR 1/2' THRU 1-1/4': M5.0x.8-16LG) (FDR 1-1/2' THRU 2': M6.0x1-20LG)	STAINLESS STEEL	4
4	COUPLING	STAINLESS STEEL 303	1
3	MOUNTING BRACKET	PPG	1
2	ACTUATOR SERIES 94	ZYTEL	1
1	BALL VALVE TYPE 21	PVC,CPVC,PP,PVDF	1
ITEM	DESCRIPTION	MATERIAL	QTY

HEREON IS THE PROPERTY OF ASAHI/AMERICA. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE IS FORBIDDEN WITHOUT WRITTEN CONSENT.

THIS DRAWING AND ALL INFORMATION

	NAME	DATE
DR	KENICHI MIYAZAKI	8/2/01
APPD	DAVE HURLEY	8/2/01
PROD	LEO LESTER	8/2/01
WO#/	CO#	
FILE		

ASAHI/AMERICA


ISO 9001 CERTIFIED


35 GREEN STREET, P.O. BOX 653, MALDEN, MA.



]	BALI	L VA	ALVE	TYPE	E21
SERIE	S94	4 Ele	ECTRI	CAC	CTUATOR
		1/2"	THRL] 2"	
SIZE	DWG.	NO.			REV

SIZE A DWG. NO. 0106BV A SCALE NTS SHEET 1 OF 1





VALVE SIZE 2-1/2" 3"
H 5.12 5.47
H1 2.83 3.35

NOTE. The shape and appearance of assembly differ a little with nominal size compared to this drawing.

9	FLAT WASHER (M6.0)	STAINLESS STEEL	4
8	B□LT (M6.0×1-16LG)	STAINLESS STEEL	4
7	NUT (M8.0×1.25)	STAINLESS STEEL	4
6	FLAT WASHER (M8.0)	STAINLESS STEEL	8
5	BOLT (M8.0×1.25-35LG)	STAINLESS STEEL	4
4	COUPLING	STAINLESS STEEL 303	1
3	MOUNTING BRACKET	PPG	1
2	ACTUATOR SERIES 94	ZYTEL	1
1	BALL VALVE TYPE 21	PVC,CPVC,PP,PVDF	1
ITEM	DESCRIPTION	MATERIAL	QTY

THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF ASAHI/AMERICA. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE IS FORBIDDEN WITHOUT WRITTEN CONSENT.

DR KENICHI MIYAZAKI 8/14/0 APPD DAVE HURLEY 8/14/0	14/01
BIT REMONIT HITTERING 071170	
APPD DAVE HURLEY 8/14/0	14/01
	1 17 01
PROD LED LESTER 8/14/0	14/01

ASAHI/AMERICA

ISO 9001 CERTIFIED


35 GREEN STREET, P.O. BOX 653, MALDEN, MA.

BALL VALVE TYPE21
IES94 ELECTRIC ACTUATOR
2-1/2" THRU 3"

SIZE A DWG. NO. 0112BV A

SCALE NTS SHEET 1 OF 1

FOR REFERENCE ONLY
ASAHI/AMERICA



DIMENSIONS TABLE

UNIT: inch

NON	/INAL		FLAN	GED	THRE	ADED			SOCI	KET			SPIGOT (E	BUTT END)
SI	ZE						PVC,	CPVC	PP,PVD	F (DIN)	PP,PVD)F (IPS)		
		Н	H1	L	H1	L	H1	L	H1	L	H1	L	H1	L
1/2"	15 ^{mm}	2.76	3.70	5.63	2.89	4.02	3.08	4.45	2.80	3.90	3.09	4.45	3.27	4.88
3/4	20	3.01	4.50	6.77	3.48	4.72	3.56	5.08	3.27	4.49	3.61	5.08	3.90	5.67
1	25	3.29	5.24	7.36	4.13	5.16	4.32	5.75	3.94	4.84	4.37	5.75	4.53	6.06
11/2	40	3.98	6.50	8.35	5.53	6.42	5.71	7.24	5.16	5.83	5.85	7.24	6.02	6.85
2	50	4.43	7.34	9.21	6.61	7.76	6.66	8.23	6.06	6.93	6.76	8.23	7.01	8.82
3	80	5.47	10.06	11.97	9.25	10.39	9.59	11.10	8.82	9.88	11.10	11.10	9.69	11.61

NOTE; 1) THE SHAPE AND APPEARANCE OF ASSEMBLY DIFFER A LITTLE WITH NOMINAL SIZE COMPARED TO THIS DRAWING.

2) FOR DETAILED VALVE DIMENSIONS,

REFER TO DWG. NO. 0126BV, 0127BV, 0128BV.

L-PORT: DWG. NO. 0126BV

DOUBLE L-PORT: DWG. NO. 0127BV CROSS PORT: DWG. NO. 0128BV

EOD DEEEDENCE ONI V

-OK KEFEKENCE ONL I	
ASAHI/AMERICA	
AGAITIVAITERTOA	

9	FLAT WASHER (M6.0)	STAINLESS STEEL	4
8	BOLT (M6.0×1-16LG)	STAINLESS STEEL	4
7	NUT (FDR 1/2" THRU 1" : M5.0x.8) (FDR 1-1/2" THRU 2" : M6.0x1) (FDR 3" : M8.0x1.25)	STAINLESS STEEL	4
6	FLAT WASHER (FDR 1/2" THRU 1" : M5.0) (FDR 1-1/2" THRU 2" : M6.0) (FDR 3" : M8.0)	STAINLESS STEEL	8
5	BOLT (FOR 1/2" THRU 1": M5.0x.8-16LG) (FOR 1-1/2" THRU 2": M6.0x1-20LG) (FOR 3": M8.0x1.25-35LG)	STAINLESS STEEL	4
4	COUPLING	STAINLESS STEEL 303	1
3	MOUNTING BRACKET	PPG	1
2	ACTUATOR SERIES 94	ZYTEL	1
1	MULTIPORT BALL VALVE TYPE23	PVC,CPVC,PP,PVDF	1
ITEM	DESCRIPTION	MATERIAL	QTY

THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF ASAHI/AMERICA. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE IS FORBIDDEN WITHOUT WRITTEN

	NAME	DATE			
DR	KENICHI MIYAZAKI	1/28/03			
APPD	DAVE HURLEY	1/28/03			
PROD	LEO LESTER	1/28/03			
WO#/CO#					
FILE					

ASAHI/AMERICA

ISO 9001 CERTIFIED

35 GREEN STREET, P.O. BOX 653, MALDEN, MA.

VALVE TYPE23 WITH SERIES94 ACT. 1/2" THRU 3"

_	SIZE	DWG.	NO.				REV		
	A			0129B	\vee			Α	
_	SCALE ,,-				l ,				
	l N	12			SHFFT	\cap	F]		


UNIT: INCH

VALVE SIZE	1-1/2"	2″	2-1/2"	3″	4″
Н	5.51	5.75	6.18	6.46	7.16
H1	2.95	3.27	3.66	3.94	4.53

NOTE: 1.The shape and appearance of assembly differ a little with nominal size compared to this drawing.

2. For Mounting Bracket: F07xF05, F07

FOR REFERENCE ONLY
ASAHI/AMERICA



- 5,62 ·

0

3.82 -

9	FLAT WASHER (M6.0)	STAINLESS STEEL	4
8	BOLT (M6.0×1-16LG)	STAINLESS STEEL	4
7	NUT (FOR 1-1/2" THRU, 4" : M8.0x1.25)	STAINLESS STEEL	4
6	FLAT WASHER (FOR 1-1/2" THRU, 4" : M8.0)	STAINLESS STEEL	8
5	B□LT (FDR 1-1/2' THRU, 4': M8.0x1.25-35LG)	STAINLESS STEEL	4
4	COUPLING	STAINLESS STEEL 303	1
ω	MOUNTING BRACKET	PPG	1
S	ACTUATOR SERIES 94	ZYTEL	1
1	BUTTERFLY VALVE TYPE 57	U-PVC,PP,PVDF	1
ITEM	DESCRIPTION	MATERIAL	QTY

THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF ASAHI/AMERICA. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE IS FORBIDDEN WITHOUT WRITTEN CONSENT.

	NAME	DATE		
DR	JOHN GLASSFORD	6/10/05		
APPD	DAVE HURLEY	6/10/05		
PROD	LEO LESTER	6/10/05		
WO#/CO#				
FILE				

ASAHI/AMERICA


ISO 9001 CERTIFIED


35 GREEN STREET, P.O. BOX 653, MALDEN, MA.




BUTTERFLY VALVE TYPE57 SERIES94 ELECTRIC ACTUATOR 1-1/2" THRU 4"

SIZE A	DWG. NO. 0203BF	57	REV A	
SCALE N	TS	SHEET 1 C)F 1	







ITEM	PART NO	QTY	DESCRIPTION
1	7403002	1	BASE
2	7403000	1	BASE SEAL
3	7403017	1	DUTPUT COUPLING
4	7403005	2	COUPLING GASKET
5	7403004	1	MOTOR
6	7403022	2	MOTOR SCREW
7	7403011	1	BASE PLATE
8	7401420	1	TERMINAL BLOCK 1-8
9	7401425	1	TERMINAL BLOCK 9-16
10	7401600	4	TERMINAL BLOCK SCREW
13A	7401948	1	4.2 MFD CAPACITOR - A94
13B	7402004	1	6.7 MFD CAPACITOR - B94
14	7401460	2	LIMIT SWITCH
15	7401620	2	LIMIT SWITCH SCREW
16	7403016	1	DUTER SHAFT
17	7403006	2	DUTER SHAFT GASKET
18	7403009	2	RETAINING RING
19	7403018	2	STANDOFF
20	7403014	2	BASE PLATE SCREW
21	7401480	2	CAM
22	7401740	4	CAM SCREW
23	7403010	1	PIN
24	7403023	1	2 PC HARNESS
25	7403015	1	4 PC HARNESS
26	7403007	1	BASE GASKET
27	7403001	1	COVER
28	7403020	1	COVER SEAL
29	7403019	1	WIRE DIAGRAM LABEL
30	7403025	1	OPTION LABEL
31	7403030	1	QM II LABEL
32	7403040	1	OVERRIDE LABEL
33	7403032	8	COVER SCREW
34	7403003	1	HANDLE
35	7401700	1	HANDLE SCREW
36	7403021	1	QM II BOX

- NOTE:
 1. LOCATE ITEM 29 & 30 DN INSIDE SURFACES
 DF COVER (ITEM 27).
 2. LOCATE ITEM 31 DN GUTSIDE BACK SURFACE
 DF COVER (ITEM 27).

FOR REFERENCE ONLY ASAHI/AMERICA

THIS DRAWING AND ALL INFORMATION HEREON IS THE PROPERTY OF ASAHI/AMERICA. ANY COPYING, REPRODUCTION OR UNAUTHORIZED USE IS FORBIDDEN WITHOUT WRITTEN CONSENT.

	NA	ME	DATE				
DR	D	CAMERON	9/13/01				
APP	D DA	VE HURLEY	9/13/01				
PRO	D LE	D LESTER	9/13/01				
WO#							
FILE	AC	ACAD11/QM					

ASAHI/AMERICA ISO 9001 CERTIFIED

35 GREEN STREET, P.O. BOX 653, MALDEN, MA.



SERIES 94 EXPLODED VIEW

SIZE A	DWG. NO.	279QM			REV	В
SCALE N	TS		SHEET 1	0	F	1